



**BIDS AND AWARDS COMMITTEE**  
**INFRASTRUCTURE & REPAIRS**

May 18, 2022

**Bid Bulletin No. 1**  
**Modifications in the Bill of Quantities**

This Supplemental/ Bid Bulletin no. 1 dated May 18, 2022 for the project “Construction of Engineering Building Phase III, BulSU Malolos, Bulacan (INFRA-2022-02)”, is issued to modify or amend the items in the Bid Documents. Accordingly, this shall form an integral part of said Documents.

**I. SECTION VIII. BILL OF QUANTITIES**  
**ELECTRICAL WORKS**  
**Item A.1.0, B.1.0, C.1.0, D.1.0 and E.1.0**

**A.ELECTRICAL WORKS- GROUND FLOOR**

	FROM	TO
Item No.	Description	Description
<b>1.0 LIGHTING FIXTURES AND WIRING DEVICES (incl. Consumables)</b>		
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<b><u>Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</u></b>
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<b><u>Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</u></b>
	X	X

Note:

1. Item, description, quantity and unit not mentioned above are without modifications and will remain as it is in the bidding documents
2. Modified/additional entries are underlined, bold, italicized and highlighted

**B. ELECTRICAL WORKS- SECOND FLOOR**

	FROM	TO
Item No.	Description	Description
<b>1.0 LIGHTING FIXTURES AND WIRING DEVICES (incl. Consumables)</b>		
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	x	x

Note:

1. Item, description, quantity and unit not mentioned above are without modifications and will remain as it is in the bidding documents
2. Modified/additional entries are underlined, bold, italicized and highlighted

**C. ELECTRICAL WORKS- THIRD FLOOR**

	FROM	TO
Item No.	Description	Description
<b>1.0 LIGHTING FIXTURES AND WIRING DEVICES (incl. Consumables)</b>		
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	x	x

Note:

1. Item, description, quantity and unit not mentioned above are without modifications and will remain as it is in the bidding documents
2. Modified/additional entries are underlined, bold, italicized and highlighted



**E. ELECTRICAL WORKS- FOURTH FLOOR (In the BOQ-Bidding Documents)**  
**Should be: D. ELECTRICAL WORKS- FOURTH FLOOR**

	FROM	TO
Item No.	Description	Description
<b>1.0 LIGHTING FIXTURES AND WIRING DEVICES (incl. Consumables)</b>		
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	X	X

Note:

1. Item, description, quantity and unit not mentioned above are without modifications and will remain as it is in the bidding documents
2. Modified/additional entries are underlined, bold, italicized and highlighted


**E. ELECTRICAL WORKS- FIFTH FLOOR**

	FROM	TO
Item No.	Description	Description
<b>1.0 LIGHTING FIXTURES AND WIRING DEVICES (incl. Consumables)</b>		
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x300x80; 2 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	<b>Surface</b> /Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8	<u><b>Recessed Type LED Tube Panelight with louver reflector 1200x150x80; 1 x 18W; 30,000 life hrs; 1800 lumens; 200 beam angle; T8.</b></u>
	X	X

Note:

1. Item, description, quantity and unit not mentioned above are without modifications and will remain as it is in the bidding documents
2. Modified/additional entries are underlined, bold, italicized and highlighted

For guidance and information of all concerned.

  
**ISABELITA C. BENEDICTOS, CPA, MPA**  
 Chairperson, BAC for Infrastructure and Repairs 