



Republic of the Philippines  
**BULACAN STATE UNIVERSITY**  
 City of Malolos, Bulacan

Tel. No. (044) 796-2160, 791-0153; Fax No. (044) 662-0455

**Bid Bulletin No. 1**

**Modifications in the BDS, Specifications and SCC**

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents for the **“INSTALLATION AND UPGRADING OF SERVICE ENTRANCE TO 3-PHASE FLORES HALL (12-09)”** to wit;

**1. BDS**

ITB Clause	From	To
12.1(b)(ii.2)	Registered Electrical Engineer (Valid PRC License)	<b><u>Professional Electrical Engineer (Valid PRC License)</u></b>
12.1(b)(iv)	g.	<b><u>g. Contractor's Conforme (Construction Specifications)</u></b>
24.1	The date and time of bid opening is December 19, 2012, 1:30 p.m.	The date and time of bid opening is <b><u>December 20, 2012, 1:30 p.m.</u></b>

**2. SPECIFICATION**

	From	To
IV. Materials and Workmanship  V. Specifications	<p>a. shall be new and of high quality d. "TW"</p> <p>3.0 Power Cables</p> <p>3-a The power cable to be supplied and installed shall 200mm<sup>2</sup>, 50mm<sup>2</sup>, 30mm<sup>2</sup>, 22mm<sup>2</sup>, 8.0mm<sup>2</sup> and 5.5mm<sup>2</sup>.</p> <p>3-b The power cable shall be soft annealed copper , insulated with a tough heat and moisture resistant and flame retardant polyvinyl chloride (PVC) hard plastic of highest quality, with oil, chemical and abrasion resistant nylon (polyamide) sheath.</p> <p>5.0 Others</p> <p>5-b During bid opening enclose sample of wires in lieu of wires brochures/literatures to be included in technical envelope.</p> <p>5-c Top 3 brands and heavy duty items only are acceptable.</p>	<p><b><u>a. shall be new and high quality</u></b> <b><u>d. "THHN"</u></b></p> <p>3.0 Power Cables</p> <p>3-a The power cable to be supplied and installed shall <b><u>be</u></b> 200mm<sup>2</sup>, 50mm<sup>2</sup>, 30mm<sup>2</sup>, 22mm<sup>2</sup>, 8.0mm<sup>2</sup> and 5.5mm<sup>2</sup>.</p> <p>3-b The power cable shall be soft annealed copper , insulated with a tough heat and moisture resistant and flame retardant polyvinyl chloride (PVC) <b><u>hard plastic of highest quality</u></b>, with oil, chemical and abrasion resistant nylon (polyamide) sheath.</p> <p>5.0 Others</p> <p>5-b During bid opening wire brochures/literatures should be included in the technical envelope <b><u>and accompanied by sample of wires wrapped or placed in a bag.</u></b></p> <p>5-c <b><u>Top 2 brands and heavy duty items only are acceptable.</u></b></p>

**3. SCC**

GCC Clause	From	To
1.16	The intended Completion Date is Fifteen (15) working days from receipt of Notice to Proceed	<b><u><i>The intended Completion Date is Thirty (30) calendar days from receipt of Notice to Proceed</i></u></b>

**Note: Modified/additional entries are in bold, underlined and italicized fonts.**

For the information and guidance of all concerned.

Very truly yours,

(Sgd.) EVANGELINA G. CUSTODIO, Ed.D.  
BAC, Chairperson

***beth c")12/07/12***