



Republic of the Philippines
BULACAN STATE UNIVERSITY
 City of Malolos, Bulacan

Tel. No. (044) 796-2160, 791-0153; Fax No. (044) 662-0455

Bid Bulletin No. 1

Modifications in the BDS, Specifications and SCC

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents for the **“INSTALLATION AND UPGRADING OF SERVICE ENTRANCE TO 3-PHASE FLORES HALL (12-09)”** to wit;

1. BDS

ITB Clause	From	To
12.1(b)(ii.2)	Registered Electrical Engineer (Valid PRC License)	<u>Professional Electrical Engineer (Valid PRC License)</u>
12.1(b)(iv)	g.	<u>g. Contractor's Conforme (Construction Specifications)</u>
24.1	The date and time of bid opening is December 19, 2012, 1:30 p.m.	The date and time of bid opening is <u>December 20, 2012, 1:30 p.m.</u>

2. SPECIFICATION

	From	To
IV. Materials and Workmanship V. Specifications	a. shall be new and of high quality d. "TW" 3.0 Power Cables 3-a The power cable to be supplied and installed shall 200mm ² , 50mm ² , 30mm ² , 22mm ² , 8.0mm ² and 5.5mm ² . 3-b The power cable shall be soft annealed copper , insulated with a tough heat and moisture resistant and flame retardant polyvinyl chloride (PVC) hard plastic of highest quality, with oil, chemical and abrasion resistant nylon (polyamide) sheath. 5.0 Others 5-b During bid opening enclose sample of wires in lieu of wires brochures/literatures to be included in technical envelope. 5-c Top 3 brands and heavy duty items only are acceptable.	<u>a. shall be new and high quality</u> <u>d. "THHN"</u> 3.0 Power Cables 3-a The power cable to be supplied and installed shall <u>be</u> 200mm ² , 50mm ² , 30mm ² , 22mm ² , 8.0mm ² and 5.5mm ² . 3-b The power cable shall be soft annealed copper , insulated with a tough heat and moisture resistant and flame retardant polyvinyl chloride (PVC) <u>hard plastic of highest quality</u> , with oil, chemical and abrasion resistant nylon (polyamide) sheath. 5.0 Others 5-b During bid opening wire brochures/literatures should be included in the technical envelope <u>and accompanied by sample of wires wrapped or placed in a bag.</u> 5-c <u>Top 2 brands and heavy duty items only are acceptable.</u>

3. SCC

GCC Clause	From	To
1.16	The intended Completion Date is Fifteen (15) working days from receipt of Notice to Proceed	<u><i>The intended Completion Date is Thirty (30) calendar days from receipt of Notice to Proceed</i></u>

Note: Modified/additional entries are in bold, underlined and italicized fonts.

For the information and guidance of all concerned.

Very truly yours,

(Sgd.) EVANGELINA G. CUSTODIO, Ed.D.
BAC, Chairperson

beth c")12/07/12