



BIDS AND AWARDS COMMITTEE INFRASTRUCTURE & REPAIRS

Bid Bulletin No. 2 Modifications in the Invitation to Bid and Bill of Quantities

This Supplemental/ Bid Bulletin no. 2 dated October 6, 2020 for the project **"CONSTRUCTION OF ENGINEERING BUILDING PHASE III (BULSU MALOLOS CAMPUS) Infra-2020-18"**, is issued to modify or amend the items in the Bid Documents. Accordingly, this shall form an integral part of said Documents.

I. INVITATION TO BID & BID BULLETIN NO. 1

	FROM	TO
5	<p>A complete set of Bidding Documents may be acquired by interested Bidders on September 22, 2020 from the address below and upon payment of a fee in the amount of Fifty Thousand Pesos (₱ 50,000.00). BulSU implements a four-day work week (Tuesday to Friday) 7:30 a.m. to 6:30 p.m., until further notice.</p> <p>It may also be downloaded free of charge from the website of the PhilGEPS and the website of the BulSU, provided that Bidders shall pay the applicable fee for the Bidding Documents not later than October 13, 2020.</p>	<p>A complete set of Bidding Documents may be acquired by interested Bidders on September 22, 2020 from the address below and upon payment of a fee in the amount of Fifty Thousand Pesos (₱ 50,000.00) <u>to the Cashier's Office Bulacan State University, City of Malolos, Bulacan, during office hours from 8:00 a.m. to 5:00 p.m., Monday to Friday (Except on holidays).</u></p> <p>It may also be downloaded free of charge from the website of the PhilGEPS and the website of the BulSU, provided that Bidders shall pay the applicable fee for the Bidding Documents not later than October 15, 2020.</p>
Bid Bulletin no. 1	<p>Submission of Bids</p> <p><i>On or before</i> October 15, 2020 (Thursday), 2:00 pm</p>	<p>Submission of Bids</p> <p><i>On or before</i> October 15, 2020 (Thursday), 2:00 pm</p>


BAC Office, Hostel 3rd Floor, BulSU Main Campus, City of Malolos, Bulacan	<p>BAC Office, Hostel 3rd Floor, BulSU Main Campus, City of Malolos, Bulacan</p> <p><u>Reminder:</u></p> <p><u>As part of the Bulacan State University COVID-19 Health Protocols, all visitors with appointment must go directly to the University Infirmary before proceeding to their office destination. A Client disclosure form must be accomplished at the University Infirmary.</u></p> <p><u>In this regard, a temporary pass from University Infirmary shall be presented to the BAC Secretariat before submission of bids.</u></p>
---	---

II. BILL OF QUANTITIES (SECTION VIII)

	FROM	TO
	STRUCTURAL WORKS	STRUCTURAL WORKS
I.	<p>CONSTRUCTION OF THE FOLLOWING STRUCTURES:</p> <p>1.00 LOT</p> <p>Pump Room</p> <p>Cistern Tank for Clean Water</p> <p>Cistern Tank for Fire Protection</p> <p>Cistern Tank for Water Harvesting</p> <p>Filter Tank</p>	<p>CONSTRUCTION OF THE FOLLOWING STRUCTURES:</p> <p>1.00 LOT</p> <p><u>1) Temporary Enclosure (5m x 6.5m) to House the Pumps including the GI Roofing Sheets, Dry Wall (Ficem Board) for Sidings with Temporary Lightings and Outlets</u></p> <p><u>2) Cistern Tank for Clean Water, Cistern Tank for Fire Protection, Rainwater Impounding Tank with Filtration</u></p> <p><u>With the following:</u></p> <p><u>a) Integral Waterproofing by Crystallization (each structure)</u></p> <p><u>b) Rebars</u></p> <p><u>Walls</u></p> <p><u>2 Layers - 16mmØ vertical bars @0.20m o.c. and 12mmØ horizontal bars @0.20m o.c.</u></p> <p><u>Floor & Top Slab (top & bottom bars)</u></p>

		<u>16mmØ transverse bars @0.20m o.c. with 12mmØ longitudinal bars @0.20m o.c.</u> <u>c) Waterstop must be provided on construction joints</u> <u>All works are subject to BulSU Engineer's approval.</u>
	AUXILIARY WORKS	
I.	STRUCTURED CABLING FOR VOICE AND DATA 1.00 LOT Roughing-ins	STRUCTURED CABLING FOR VOICE AND DATA 1.00 LOT Roughing-ins <u>Use Electrical Metal Tube (EMT) for the conduit complete with boxes and fittings</u>
II.	FIRE DETECTION AND ALARM SYSTEM SYSTEM 1.00 LOT Roughing-ins	FIRE DETECTION AND ALARM SYSTEM SYSTEM 1.00 LOT Roughing-ins <u>Use Electrical Metal Tube (EMT) for the conduit complete with boxes and fittings</u>
III.	CCTV SYSTEM 1.00 LOT Roughing-ins	CCTV SYSTEM 1.00 LOT Roughing-ins <u>Use Electrical Metal Tube (EMT) for the conduit complete with boxes and fittings</u>

For guidance and information of all concerned.


ROMEO DC. INASORIA, DPA **10/6/20**
Chairperson, BAC for Infrastructure and Repairs

Received by: _____
Name of Representative of the Bidder

Name of Company

Date Received: _____