



Republic of the Philippines  
**BULACAN STATE UNIVERSITY**  
City of Malolos, Bulacan

## **BIDS AND AWARDS COMMITTEE INFRASTRUCTURE & REPAIRS**

---

September 14, 2021

### **Bid Bulletin No. 1 Modifications in the Invitation to Bid and Bill of Quantities**

This Supplemental/ Bid Bulletin no. 1 dated September 14, 2021 for the project “**EXTENSION OF CCJE AND CSSP BUILDING (Infra-2021-10)**”, is issued to modify or amend the items in the Bid Documents. Accordingly, this shall form an integral part of said Documents.

#### **I. INVITATION TO BID (SECTION I)**

	<b>FROM</b>	<b>TO</b>
7	Bids must be duly received by the BAC Secretariat through manual submission at the office address as indicated below, on or before September 27, 2021 (Monday), 1:30 p.m. Late bids shall not be accepted.	<b>Submission of Bids</b>  <b><i>Postponed until further notice</i></b> due to imposition of Modified Enhanced Community Quarantine (MECQ) in the province of Bulacan until September 30, 2021.
9	Opening of bids shall be on <b>September 27, 2021 (Monday), 1:30 p.m.</b> at the Valencia Hall, BulSU Main Campus, City of Malolos, Bulacan 3000. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.	<b>Opening of Bids</b>  <b><i>Postponed until further notice</i></b> due to imposition of Modified Enhanced Community Quarantine (MECQ) in the province of Bulacan until September 30, 2021.

#### **II. BILL OF QUANTITIES (SECTION VIII)**

	FROM	TO
<b>SECTION XIII. ELECTRICAL WORKS</b>		
<b>3. Lighting Devices</b>		
e.	<b>Description</b> 2 Heads (24 x 0.06 Watts LED) 6V 4.5Ah Sealed Lead Acid // (for Faculty room, Gym & Fraternity office; Classroom 2A, 2B & Forensic Lab)	<b>Description</b> <u><i>Rechargeable Twinhead Emergency Lamp, 220V 60Hz, 2 Heads (24 x 0.06 Watts LED) 6V 4.5Ah Sealed Lead Acid // (for Faculty room, Gym &amp; Fraternity office; Classroom 2A, 2B &amp; Forensic Lab)</i></u>
<b>4. Protective Device</b>		
c.	<b>Description</b> Center MDP: 300AMP, 3P, BOLT-ON, - Circuit Breaker Enclosure NEMA 3R //	<b>Description</b> <u><i>10 Branches Panel board - Center MDP: 300AMP, 3P, BOLT-ON, -Circuit Breaker Enclosure NEMA 3R //</i></u>

**Notes:**

- 1. Specifications/requirements/description not mentioned above will remain as it is in the bidding documents, and**
- 2. Modified/additional entries are underlined, bold, italicized and highlighted.**

For guidance and information of all concerned.



**ISABELITA C. BENEDICTOS**

Chairperson, BAC for Infrastructure and Repairs